

CERTIFICATE ■ CERTIFICATO ■ ZERTIFIKAT ■ SERTIFIKA ■ CERTIFICADO ■ گواهینامه ■ ΠΙΣΤΟΠΟΙΗΤΙΚΟ ■ 証明書 ■ 証明書 ■ شهادة



CERTIFICATE

TYPE APPROVAL

Certificate No. 16-PEM-0010012-TIC/01

We hereby certify that

FAST PIPE
models

Tubo 3/8" sistema Fast Pipe con raccordi di estremità
Tubo 1/4" sistema Fast Pipe con raccordi di estremità

Manufacturer*: TECNOGAS S.r.l.
Viale Leonino da Zara 10
35020 Albignasego PD - ITALIA

Assembled in compliance with the assembly and crimping instruction
"Sistema FAST PIPE Installation Instruction rev. del 26.04.2016"

Have the following performance according to the applicable standards:
Permeability, no leakage (< 20 g/m² year) according to
UNI EN 1736:01

Pressure test, no leakage according to SAE J517 FEB 2013 - 12.1.2

as a result of assembly and crimp tests carried out at

TECNOGAS S.r.l. On **28/04/2016**
Via Leonino da Zara 10 – Albignasego PD

and the laboratory tests

See REPORT No. TR-0616-VIF-TIC-PC-0200012-16_02

The process of assembly and crimping

"Sistema FAST PIPE Installation Instruction"

IS APPROVED

Validity 27/04/2019

Note: (*)The manufacturer declares that the products are built using the same materials, components and processes used for the tested prototypes. Any design change, materials, components or production process requires repetition of the tests in order to maintain the validity of the certificate. The certificate is issued for the model tested and based on a voluntary request of the manufacturer. It is not extended to the manufacturing process.



Reggio Emilia, 01/06/2016

Ing. Andrea Vivi
TUV INTERCERT Certification Body

